

Supplier Declaration of Conformity (SDOC)

(in accordance with ISO/IEC 17050-1:2004)



SDoC Identification Number: NHPNLINE.002

NHP Electrical Engineering Products (N.Z.) Ltd

118a Carbine Road
Mt Wellington
Auckland 1060
New Zealand
NZ Company No: 931377
Telephone +64 9 276 1967
Fax +64 800 329 647
www.nhp-nz.com

NHP Electrical Engineering Products Pty Ltd

43-67 River Street
Richmond
Victoria 3121
Australia
A.B.N. 84 004 304 812
Telephone +61 3429 2999
Fax +61 3429 1075
www.nhp.com.au

Product details:

Product model:

NHP NLINE Item Number:
NL140L and NL340L

Description/Ratings:

Rated Current: 40A
IP Rating: IP66
Voltage rating: 250V 50Hz (NL140L) / 500V 50Hz (NL340L)
Number of Switching Poles: 2 (NL140L) / 3 (NL340L)
Switch Rating - AS/NZS60947.3: AC21A 40A, AC22A 40A, AC23A 20A.
M-Rating - AS/NZS3133: M180 (NL140L & NL340L)
Isolating Switch: Suitable for isolation in Overvoltage category III in the distribution side.
Country of origin: PRC

The products listed above is in conformity with the following Standard(s)/Normative Documents:

Standard/Document:

AS/NZS 3133:2013+A1-A2 and AS/NZS 3100:2017+A1
AS/NZS 60947.3:2015 Limited testing to test sequences I and II
AS 60529.

Test reports/Certificates:

Certificate of Suitability
Cert No.: AZ 69023432

Product Markings:

Authorised Marking: RCM and TUV023432E



Name: Christian James

Position: Product Development Manager

Date: 09/12/2021

**Signature of
Authorised Person:**

