



LABORATORY
REG. No. 1149

Parkside Laboratories (Aust)

TEST AND CERTIFICATION SERVICES

This laboratory is registered by the National Association of Testing Authorities, Australia. The tests reported herein have been performed in accordance with its terms of registration.

Laboratory Test Report

Report No.: 1272/1

Date Issued: 12 December 2003

*This report may not be reproduced except in full.
It contains no corrections or erasures.*

SUBJECT: Cubic switchboard assembly "Cubic Test Panel 2" with various module types, sizes and protecting devices. For details of module types, sizes and protecting devices refer herein. 415V 50Hz.

REQUESTED BY: CUBIC Modulsystem A/S
SKJOLDBORGS GADE 21,
DK700 BROENDERSLEV,
DENMARK

INSTRUCTIONS: Standard internal arcing-fault tests with the prospective short-circuit current of 63kA to APPENDIX "ZD" of AS 3439.1-2002
"Low-voltage switchgear and controlgear assemblies
Part 1. Type-tested and partially type-tested assemblies"

CONTENTS:	Page:
General	2
Test Specification	2
Date of Test	2
Description	3
Results	4

SUMMARY: The tested modules with associated protecting devices passed the appropriate tests described herein.

NATA APPROVED SIGNATORY: Antony K. Milovac

PREPARED BY: Steve Kon
Test Engineer

GENERAL

- a As detailed in this report, six modules specified in DESCRIPTION were tested.
- b The results detailed in this report were based on the sample submitted by the manufacturer with order No. 150356.
- c The test samples were subjected to the relevant clauses as stated herein.
- d Power supplies used were mains derived a.c. voltage sources of substantially sinusoidal waveform with a nominal frequency of 50Hz unless otherwise noted.
- e Dates of high current tests are shown on oscillograms.
- f Note: N/R means Not Relevant, N/T means Not Tested, DNC means Did Not Comply, T.O. means Test Object.

WITNESSES:

Lars Poulson	CUBIC
Jorn Jacobsen	CUBIC
Bill Mairs	NHP
Stephen Barker	NHP

TEST SPECIFICATION

AS/NZS 3439.1:2002

Low-voltage switchgear and controlgear assemblies –
Part 1: Type-tested and partially type-tested assemblies

DATE OF TEST

The testing was performed from 27th to 30th October 2003.